

CERTIFICATE OF INSTALLATION

FOR THE

PLASTEEL® ELUTRON® UNDERGROUND TANK

In compliance with part 280 of Title 40 of the Code of Federal Regulations, this document may be implemented to meet Subpart B, paragraph 280.2 (e), CERTIFICATION OF INSTALLATION.

The tank owner or owner's installer must initial all sections below representing that the installer has read, was cognizant of and has completed, as applicable, all sections of the **PLASTEEL® ELUTRON®** Tank Installation Instructions attached hereto.

Return completed and signed certificate to the manufacturer within 60 days of the installation completion date to activate warranty.

INSTALLATION CHECK-OFF COMPLETION LIST

SECTION	INITIAL	DATE
I. GENERAL	_____	_____
II. VISUAL INSPECTION	_____	_____
III. HANDLING	_____	_____
IV. EXCAVATION DEPTH, BEDDING AND BACKFILL	_____	_____
V. ANCHORING SYSTEMS	_____	_____
VI. TESTING	_____	_____
VII. VENTING: JACKETED	_____	_____
VIII. PLASTEEL® SEALING PROCEDURES	_____	_____

INSTALLATION DESCRIPTION

INSTALLATION SITE

ADDRESS

CITY, STATE, ZIP

PLASTEEL® TANK OWNER

NAME

ADDRESS

CITY, STATE, ZIP

SIGNATURE

DATE

FORM INST CERT - 0900E

RETURN COMPLETED FORM TO MANUFACTURER TO ACTIVATE WARRANTY

ELUTRON® TANK DATA

The U.L. Label and serial number is on the top centerline of the tank and also listed on the delivery document.

SIZE IN GALLONS

U.L. SERIAL NUMBER

TANK INSTALLATION COMPLETION DATE

INSTALLATION COMPANY

NAME

ADDRESS

CITY, STATE, ZIP

()

TELEPHONE

INSTALLATION COMPLETION/SUPERVISOR'S SIGNATURE

The responsible supervisor's signature below represents that phases I through VIII were properly completed per the PLASTEEL® ELUTRON® Installation Instructions:

SIGNATURE

DATE

PRINT NAME

YOUR PLASTEEL® TANK MANUFACTURER IS:

TrueNorth Steel

420 Main Ave E.

West Fargo, ND 58078

PH : (701) 492-4425

BY CHECKING THE BOX TO THE LEFT, TANK PURCHASER, INSTALLER AND/OR OWNER ACKNOWLEDGES RECEIPT OF THE WATER REMOVAL RECOMMENDED PRACTICES.

CERTIFICATE OF COMPLETION

Interstitial Vacuum Test (IVT)

For The PLASTEEL® Double-Wall Underground Tank

I. Third Party Evaluation: This leak tightness test method has been third party evaluated per the Alternate EPA Test Protocols for Plasteel International. The third party environmental consulting firm that performed the evaluation was:

Ken Wilcox Associates, Inc.
19401 E. 40 Highway, Suite 100
Independence, MO 64055
(816) 795-7997

A copy of the evaluation is on file at each licensed PLASTEEL® tank manufacturer and at:

Plasteel International Inc.
2541 State Street
Carlsbad, CA 92008
(760) 729-1093

II. Tank Description:

Capacity: _____ Gallons

Jacketed: _____

Composite: _____

Compartmented: Yes _____ No _____

U.L. Number _____

Tank Manufacturer:

Name: TrueNorth Steel

Address: 420 Main Ave E.

West Fargo, ND 58078

III. Installation Information:

Tank Owner:

Name: _____

Address: _____

Installation Location:

IV. Test Results: The interstitial vacuum test was performed per Appendix B. The following data was recorded:

Nominal Tank Capacity: _____
(Gallons)

Primary Tank Product: _____
(air, gasoline, diesel, water)

Required Test Period: _____
(Hours, per Appendix B, Figure 6.0)

Initial Gauge Reading: _____ inches Hg.
Date _____ Time _____ am/pm

Final Gauge Reading: _____ inches Hg.
Date _____ Time _____ am/pm

Total Elapsed Time Period: _____
(Hours)

Pass _____ Fail _____ (Initial)

V. Statement of Test: I certify that the PLASTEEL® Double-Wall tank described above has been tested leak tight per Appendix B of the PLASTEEL® Tank Installation Instructions.

Testing Company:

Name: _____

Address: _____

Telephone: _____

Signature

Printed Name

Title

Date

■ ■ ■ ■ WARRANTY ■ ■ ■ ■

PLASTEEL® ELUTRON® Underground Petroleum/Motor Fuel Storage Tank

TANK OWNER NAME: _____

TANK OWNER ADDRESS: _____

TANK INSTALLATION ADDRESS: _____

TANK U.L. NUMBER: _____

TANK CAPACITY: _____

SHIPMENT DATE: _____

MANUFACTURER NAME: TrueNorth Steel
420 Main Ave E.

MANUFACTURER ADDRESS: West Fargo, ND 58078

MANUFACTURER TELEPHONE: (701) 492-4425

The manufacturer above is pleased to extend, on the U.L. numbered tank and installation above, when installed per our instructions, installed per N.F.P.A. Standard 30 for underground steel tanks, and upon receipt of completed and signed Certificate of Installation within 60 days of the installation completion date, the following warranty:

Provided that (i) Manufacturer shall have received a completed and signed Certificate of Installation from the tank owner in the form prescribed by Manufacturer, (ii) the tank in question shall have been installed in accordance with Manufacturer's installation instructions, and (iii) *the subject tank is maintained in accordance with **Steel Tank Institute** "Recommended Practice for Storage Tank Maintenance R111 Revision, 2nd Edition, March 2016", **Clean Diesel Fuel Alliance**, "Guidance for Underground Storage Tank Management at USLD Dispensing Facilities" and the **Coordinating Research Council (CRC) Report 672, July 2016, whichever is most applicable.***

The manufacturer above warrants the subject **PLASTEEL® ELUTRON® Underground Tank** when maintained per the recommended practices as listed as listed above:

1. *to be free from defect in workmanship and materials for a period of five (5) years from the date of shipment;*
2. *will not fail due to internal or external corrosion for a period of thirty (30) years from the date of shipment when used to store all motor fuels, including but not limited to, unleaded gasoline, leaded gasoline, gasohol in any alcohol blend percentages, 100% methanol, 100% ethanol, diesel fuel, jet fuel, kerosene, and fuel oil. Liquids are to be stored at atmospheric pressure and at a temperature not to exceed 150° (66°C). Consult manufacturer concerning other warranted liquids.*

The Warranty is specifically limited to the manufacturer's choice of one of the remedies set forth below in the event of a proven claim:

1. *Repair of the tank at our factory, freight charges not included.*
2. *Replacement of tank delivered to point of original delivery.*
3. *Refund of the original purchase price.*

This Warranty will be void unless written approval from the manufacturer, at our discretion, is effected before:

1. *Modification (s) is/are performed on the tank.*
2. *The tank is removed from the intended service.*
3. *The buried tank is removed to above grade.*

Owner must provide the manufacturer the opportunity to observe and inspect the tank prior to the removal of the buried tank to aboveground.

We are not liable for any labor, other installation or removal costs, indirect or consequential damages or any other damages in connection with these tanks.

Except as stated above, we make no warranty of merchantability, no warranty that our underground **PLASTEEL® ELUTRON®** tanks are fit for any particular purpose or use and no other warranty express or implied.